## RESOLUTION

## Lake County Board of Health June 24, 2008

A resolution to allow for a standard variance to Lake County Wastewater Treatment System Regulations that may be administered by staff of the Environmental Health Department when specific criteria are met.

WHEREAS, the Lake County Board of Health has authority under A.R.M. 17.36.922 Local Variances and Lake County Wastewater Treatment System Regulations to grant variances to the state minimum standards for on-site wastewater treatment systems, and

WHEREAS, there are certain re-occurring circumstances under which the Lake County Board of Health would grant a variance without the usual hearing being necessary or desirable;

## NOW THEREFORE BE IT RESOLVED:

That, effective this date, the Lake County Environmental Health Department may issue installation and use permits for drip irrigation wastewater treatment systems that meet the following criteria:

- 1. The system location meets or exceeds all minimum separation distances required by the Lake County Wastewater Treatment System Regulations with the optional exception of setback to slope requirements.
- 2. The system design meets or exceeds all requirements of the Lake County Wastewater Treatment System Regulations with the exception of drainfield trench design.
- 3. The system design meets or exceeds all requirements of the manufacturer's specifications for drip irrigation of wastewater.
- 4. The system design incorporates a Level II unit for the advanced treatment and superfiltration of the wastewater effluent.
- 5. The advanced treatment unit must have a perpetual maintenance agreement through an independent agent that is filed with the Lake County Clerk & Recorder's Office.
- 6. The Lake County Environmental Health Department reserves the right to require any system requiring a variance be heard before the Lake County Board of Health if it deems the site conditions warrant a full Board review.

6-24-08

Chairman

Lake County Board of Health